

CERTIFICATE OF COMPLIANCE

Certificate Number 20150512-S25094
Report Reference S25094-20150429
Issue Date 2015-MAY-12

Issued to: NITTAN CO LTD
54-5, 1-CHOME SASAZUKA
SHIBUYA-KU
TOKYO 151-8535 JAPAN

**This is to certify that
representative samples of**

SMOKE-AUTOMATIC FIRE DETECTORS; HEAT-
AUTOMATIC FIRE DETECTORS

Photoelectric, analog addressable, Model EVA-PY, smoke
detector head. Photoelectric, analog addressable, Model
EVA-PYH, Smoke/heat detector head, with 135 °F fixed
temperature and 15 °F Rate Of Rise temperature
thermistor.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/UL 268, Standard for Safety for Smoke Detectors for
Fire Alarm Systems. ANSI/UL 521, Standard for Safety for
Heat Detectors for Fire Protective Signaling Systems

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

