

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150505-S25094  
**Report Reference** S25094-20150430  
**Issue Date** 2015-MAY-05

**Issued to:** NITTAN CO LTD  
54-5, 1-CHOME SASAZUKA, SHIBUYA-KU  
TOKYO 151-8535 JAPAN

**This is to certify that  
representative samples of**

SMOKE-AUTOMATIC FIRE DETECTORS, AUDIBLE-SIGNAL APPLIANCES , HEAT-AUTOMATIC FIRE DETECTORS

Fire Alarm Subassembly  
Addressable Sounder Base, model EVA-S6 Base.  
Relay Base, model EVA-STB-RL.  
Isolator Base, model EVA-STB-SCI  
For use with models EVA-PY, EVA-PYH, EVA-DPH, and EVA-H2.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**


ANSI/UL 268 Standard for Safety for Smoke Detectors for Fire Alarm Systems  
ANSI/UL 521 Standard for Safety for Heat Detectors for Fire Protective Signaling Systems  
ANSI/UL 464 Standard for Safety for Audible Signal Appliances

**Additional Information:**

See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

