



The mentioned product complies with the mentioned test requirement

# Intertek LSS Scheme Tick Mark Certificate

18LHK0938-01

In accordance with the Tick Mark Rules and Certification System 5, as defined in ISO / IEC 17067:2013, we certify that the product(s)

## EV Range of Input / Output Modules

are in conformity with the following standard(s):  
**EN54-17:2005+AC:2007, EN54-18:2005+AC:2007**

Report Number(s):  
102788845LHD-021, 102788845LHD-022

**Nittan Europe Limited**  
Hipley Street, Old Woking, Surrey, GU22 9LQ, United Kingdom

is authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product(s)

This certificate is valid until:  
**28-April-2023**

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee, and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

<b>Limitations:</b>	<b>Certification Body:</b> ITCL
No limitations apply.	<b>LSS Reference:</b> LSS 0919
	<b>Issued Date:</b> 29-April-2019

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



010

Certification Officer

*N.A. Jones*  
Nick Jones





The mentioned product complies with the mentioned test requirement

# Intertek LSS Scheme Tick Mark Certificate

## 18LHK0938-01

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

### ANNEX No. 1

#### Products compliant with EN54-17:2005+AC:2007 and EN54-18:2005+AC:2007:

Model	Description	Factory Code
EV-2110	Dual Input, Single Output Module (240V Mains Rated) with Integral Short-circuit Isolator	NITTANUK.02
EV-2110-EU	Dual Input, Single Output Module (240V Mains Rated) with Integral Short-circuit Isolator, European Version	NITTANUK.02
EV-3IO	Triple Input / Output Module (One 240V Mains Rated Relay) with Integral Short-circuit Isolator	NITTANUK.02
EV-MiniIP2	Mini Input Module with Integral Short-circuit Isolator	NITTANUK.02
EV-SCM2	Dual Output Sounder Control Module with Integral Short-circuit Isolator	NITTANUK.02
EV-SCM2-EU	Dual Output Sounder Control Module with Integral Short-circuit Isolator, European Version	NITTANUK.02
EV-ZMU2	Dual Input Zone Monitor Module with Integral Short-circuit Isolator	NITTANUK.02
EV-ZMU2-EU	Dual Input Zone Monitor Module with Integral Short-circuit Isolator, European Version	NITTANUK.02
EV-IO-420	4-20mA Input / Output Module (240V Mains Rated) with Integral Short-circuit Isolator	NITTANUK.02

#### Products compliant with EN54-18:2005+AC:2007:

Model	Description	Factory Code
EV-24VRL	Detector Base with Latching Relay Output	NITTANUK.02



The mentioned product complies with the mentioned test requirement

# Intertek LSS Scheme Tick Mark Certificate

18LHK0938-01

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

## ANNEX No. 2

---

### Conditions of use:

Suitable for indoor applications only

---

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.